

1718 W. Fullerton Ave Chicago, IL 60614 Tel: 773-770-1195 Fax: 773-935-5613 www.edgelighting.com info@edgelighting.com




904-MTFJ-150-12-03



Installation Instructions for Monorail 150 Watt Surface Mount Magnetic Transformer 120 Volt Input to 12 Volt Single Feed Output with Fast Jack Port

SAVE THESE INSTRUCTIONS!




GENERAL INFORMATION

- **RISK OF FIRE:** This product must be installed by a qualified electrician. Turn the power to the electrical box off during installation. Read the "Important Safety Instructions" before installation.
- This product is suitable only for indoor dry locations and approved for the use at any height above the finished floor.
- This product contains a magnetic transformer with a built-in dimming coil.
- This product may be dimmed only with a low voltage magnetic dimmer. Using a dimmer other than specified may work initially, but will eventually cause transformer failure and void the warranty. The dimmer must be derated as indicated by the dimmer manufacturer.
- A typical installation is shown. Specific installation must be in accordance with the local electrical codes.
- Load the circuit of the surface mount transformer along with the Fast Jack port to a ${\color{red}{\bf MAXIMUM~150}}$ Watt.


IMPORTANT SAFETY INSTRUCTIONS

- Do not install this lighting system in a damp or wet location.
- Do not conceal or extend bus bar conductor through building wall.
- To reduce the risk of fire and burns, do not install this lighting system where the insulated open bus bar conductors can be shorted or contact any conductive materials.
- To reduce the risk of the system overheating and possibly causing a fire, make sure all the connections are tight.
- Do not install fixture assemblies closer than six inches, or as specified in the fixture installation instructions, to curtains or similarly combustible materials.
- Turn the electrical power off before modifying the lighting system in any way.
- The fixtures used with the Edge Lighting systems must be identified for use with the corresponding Edge Lighting systems.
- Minimum volume of the electrical box must be 6 cubic inches (98 cubic centimeters).
- The system is "ETL" listed for USA and Canada only when all the products used are supplied by Edge Lighting.


Install the Surface Mount Transformer



1: Loosen and remove the five M4 button head screws around the transformer cover with the provided 2mm Allen wrench.





2: While holding the transformer, unhook the transformer cover from the set screw.



3: Remove the inside nut and washer to remove the crossbar assembly. **DO NOT DISASSEMBLE THE CROSSBAR ASSEMBLY.**


- **4:** Connect the provided white and black extension wires to the neutral and hot power wires respectively with the wire nuts provided.
- **5:** Feed the wires through the crossbar assembly nipple.
- **6:** Place all wires and wire nut connections inside the electrical box.
- **7:** Mount the crossbar assembly to the electrical box with the two provided #8-32 screws.
- **8:** Make sure the crossbar assembly is grounded in accordance with local electrical codes.






9: Feed the extension wires through the transformer housing center hole. Slide the transformer housing onto the crossbar assembly nipple and secure it in place by tightening the washer and inside nut.

- **10:** Connect the white transformer wire to the neutral power wire with a wire nut.
- 11: Connect the black transformer wire to the hot power wire with a wire nut.




rectangle cutout, onto the Monorail feed contact set screw.




13: Place the transformer cover onto the transformer housing. Replace and tighten the five M4 button head screws with

the 2mm Allen wrench.



Install the Monorail(s) to the Transformer



Install the Fixture to the Fast Jack Port

